



City of Walnut Creek
Development Review Services
1666 N. Main Street, Walnut Creek, CA 94596
(925) 943-5834 phone (925) 256-3500 fax

Issued May 1, 2020

Policy Bulletin No. PB-032

Corrugated Stainless Steel Tubing (CSST) Gas Piping

Corrugated Stainless Steel Tubing (CSST) Gas Piping may be used in the City of Walnut Creek, subject to the following conditions:

1. CSST is only approved for residential use for occupancies that fall under HCD 1 or HCD 2, as permitted per Chapter 12 Matrix.
2. The product shall be listed per CPC 1208.6.4.4.
3. The product shall be installed in accordance with the approved listing, the approved Evaluation Report, and the manufacturer's installation standards and requirements. Copies of these documents shall be submitted to the city at the time of application for review and approval prior to the issuance of the permit.
4. Only manufacturer approved installers shall install the product.
5. Different systems cannot be mixed. That is, the installation shall not mix different manufacturer's components, unless specifically allowed in the product listing.
6. Two pressure tests shall be provided. One before wall covering and the other after wall covering. Unless the product listing specifically limits the test pressure to a lower value, test pressure shall be applied at 30 psi for 30 minutes during each test using no larger than a 60 psi calibrated pressure gauge. Per CPC 1213.3
7. CSST piping shall be bonded to the electrical service grounding electrode system per CPC 1211.2
8. CSST size piping charts 1215.2(31)-1215.2(33)